

GENERAL NOTES

THESE INSTALLATION INSTRUCTIONS ARE A SUPPLEMENT TO THE APPROVED SHOP DRAWINGS. USE IN CONJUNCTION WITH THOSE DRAWINGS.

HANDLING, STORING AND PROTECTING ALUMINUM MATERIAL

THE FOLLOWING PRECAUTIONS ARE RECOMMENDED TO ASSURE EARLY ACCEPTANCE OF YOUR PRODUCTS AND WORKMANSHIP.

- A) HANDLE CAREFULLY - DO NOT DROP FROM THE TRUCK. STACK WITH ADEQUATE SEPARATION SO MATERIAL WILL NOT RUB TOGETHER. STORE OFF THE GROUND. PROTECT AGAINST ELEMENTS AND OTHER CONSTRUCTION TRADES.
- B) KEEP MATERIAL AWAY FROM WATER, MUD AND SPRAY - PREVENT CEMENT, PLASTER AND OTHER MATERIALS FROM DAMAGING THE FINISH.
- C) PROTECT THE MATERIALS AFTER ERECTION, BY WRAPPING WITH KRAFT PAPER - OR BY ERECTING VISQUEEN/CANVAS SPLATTER SCREENS. CEMENT, PLASTER, TERRAZZO AND OTHER ALKALINE MATERIALS ARE VERY HARMFUL TO THE FINISH AND SHOULD BE REMOVED WITH WATER AND MILD SOAP BEFORE SETTING OCCURS. UNDER NO CIRCUMSTANCES ALLOW THESE MATERIALS TO DRY OR PERMANENT STAINING WILL OCCUR.

GENERAL RULES

THE FOLLOWING PRACTICES ARE RECOMMENDED FOR ALL WALL INSTALLATIONS.

- A) READ COMPLETE INSTRUCTIONS BEFORE ORDERING GLASS OR FABRICATING MATERIAL.
- B) CHECK SHOP DRAWINGS TO BECOME THOROUGHLY FAMILIAR WITH THE JOB.
- C) ALL MATERIALS ARE TO BE INSTALLED PLUMB, LEVEL AND TRUE.
- D) ALL WORK SHOULD START FROM ESTABLISHED BENCH MARKS AND COLUMN CENTER LINES ESTABLISHED BY THE ARCHITECTURAL DRAWINGS AND THE GENERAL CONTRACTOR.
- E) THE SEQUENCE OF ERECTION SHOULD BE COORDINATED WITH THE JOB SUPERINTENDENT SO DELAYS ARE PREVENTED AND RISK OF MATERIAL DAMAGE IS MINIMIZED. IF PRESETTING OF ANCHORAGE IS REQUIRED, COORDINATE WITH GENERAL CONTRACTOR AND SUPERVISE LOCATION.

- F) MAKE CERTAIN CONSTRUCTION WHICH WILL RECEIVE YOUR MATERIALS IS ACCORDING TO THE CONTRACT DOCUMENTS. IF NOT, NOTIFY THE GENERAL CONTRACTOR IN WRITING AND RESOLVE DIFFERENCES BEFORE PROCEEDING WITH YOUR WORK.
- G) INSULATE ALL ALUMINUM TO BE PLACED DIRECTLY IN CONTACT WITH THE MASONRY OR INCOMPATIBLE MATERIALS WITH A HEAVY COAT OF ZINC CHROMATE OR BITUMINOUS PAINT.
- H) FOLLOW KAWNEER INSTALLATION AND GLAZING INSTRUCTIONS.
- J) CHECK ALL MATERIAL ON ARRIVAL FOR QUANTITY.
- K) BE SURE TO HAVE ALL THE MATERIALS AND TOOLS NEEDED TO BEGIN THE INSTALLATION.
 - 1 - APPROVED SHOP DRAWINGS.
 - 2 - LEVEL AND PLUMB (TRANSIT).
 - 3 - FASTENERS AND REQUIRED DRIVERS.
 - 4 - PERIMETERS AND ACCESSORIES SUCH AS ANCHORS, FASTENERS, SLEEVES AND/OR SPLICE CAPS.
 - 5 - SEALING MATERIALS.
 - 6 - GLAZING MATERIALS.
- L) FOLLOW SEALANT MANUFACTURER'S RECOMMENDATIONS FOR PROPER SEALANT AND APPLICATION. ALL SEALANTS AND MASTICS MUST BE COMPATIBLE WITH ALL SURFACES INCLUDING OTHER SEALANT SURFACES. WHERE REQUIRED ALL SEALANTS MUST ADHERE TO ALL SURFACES INCLUDING OTHER SEALANT SURFACES.

1600 SYSTEM™2 NOTES

1600 SYSTEM™2 IS AVAILABLE WITH 1" FRAMING MEMBERS WHICH ACCEPT BOTH 1" AND 1/4" INFILLS. ALSO 1/4" FRAMING MEMBERS WHICH ACCEPT 1/4" INFILLS ONLY ARE AVAILABLE.

THE TERM "CAPTURED VERTICALS OR CAPTURED HORIZONTALS" WILL BE USED THROUGHOUT THESE INSTRUCTIONS. THIS MEANS FRAMING MEMBERS THAT ACCEPT AN EXTERIOR PRESSURE PLATE AND COVERS. "STRUCTURAL GLAZED VERTICALS" DO NOT ACCEPT EXTERIOR METAL.

GLASS BITE IS 1/2" AT CAPTURED VERTICALS AND HORIZONTALS. GLASS BITE IS 1" AT STRUCTURAL GLAZED VERTICALS. GLASS SIZES MUST BE CALCULATED FROM APPROVED SHOP DRAWINGS.


UNLESS OTHERWISE SPECIFIED, IT IS RECOMMENDED THAT SILICONE SEALANT BE USED FOR ALL INTERNAL SEALS.

SEALANT MUST BE APPLIED PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS AND PASS ALL ADHESION AND COMPATIBILITY TESTING. AT ALL JOINT SEALS, SEALANT MUST ADHERE TO METAL, GASKETS, THERMAL SEPARATOR AND JOINT PLUG MATERIALS. CLEAN ALL SURFACES PRIOR TO APPLICATION OF SEALANT AND PRIME WHERE NECESSARY TO ACHIEVE PROPER ADHESION.

VERTICAL MULLION SPLICE - VERTICAL MULLIONS THAT ARE STRUCTURALLY GLAZED MUST BE SPLICED AT A HORIZONTAL LOCATION OF THIS SPLICE MUST BE REVIEWED FOR STRUCTURAL INTEGRITY BY FACTORY ENGINEERING.

SHIM ALL SILL HORIZONTALS AT SETTING BLOCK LOCATIONS.

TYPICAL SPLICE LOCATION VISION OVER SPANDREL HORIZONTAL



CONFIDENTIAL AND PROPRIETARY INFORMATION
KAWNEER COMPANY INC.

THESE DRAWINGS ARE THE SOLE AND EXCLUSIVE PROPERTY OF KAWNEER AND CONTAIN SENSITIVE, PRIVILEGED OR CONFIDENTIAL INFORMATION WHICH MAY BE USED ONLY FOR ITS BENEFIT. THE DISCLOSURE OF THESE DRAWINGS TO UNAUTHORIZED PERSONS IS STRICTLY PROHIBITED. THIS DOCUMENT AND ALL COPIES MUST BE RETURNED UPON DEMAND.
© COPYRIGHT KAWNEER COMPANY, INC., 2012

STRUCTURAL SEAL NOTES

STRUCTURAL SILICONE SEAL - THE GLAZING INSTALLER IS RESPONSIBLE FOR SELECTING AND CONTACTING THE SILICONE MANUFACTURER TO DETERMINE WHICH TYPE OF SILICONE IS TO BE USED AND WHAT SAMPLES ARE REQUIRED TO BE SUBMITTED FOR ADHESION AND COMPATIBILITY TESTING.

THE SILICONE SEALANT SHALL NOT BE APPLIED TO KAWNEER PRODUCTS WITHOUT THE APPROVAL OF THE SILICONE MANUFACTURER AND UNTIL ALL REQUIRED TESTING IS COMPLETED AND DETAILED APPLICATION INSTRUCTIONS HAVE BEEN DELIVERED TO THE INSTALLER BY THE SILICONE MANUFACTURER.

IF YOU FIND THE SILICONE MANUFACTURER'S INSTALLATION INSTRUCTIONS ARE NOT IN ACCORDANCE WITH KAWNEER'S INSTALLATION INSTRUCTIONS, IT IS YOUR RESPONSIBILITY TO NOTIFY KAWNEER OF THIS CONFLICT PRIOR TO GLAZING.

YOUR GLASS SUPPLIER MUST BE MADE AWARE THAT THEIR GLASS WILL BE USED IN A SSG APPLICATION. THE APPLICATION MUST BE APPROVED BY THE GLASS SUPPLIER PRIOR TO GLAZING.

ANY STRUCTURAL SILICONE GLAZED PRODUCT APPLICATION THAT IS NOT SHOWN IN KAWNEER'S STANDARD PRODUCT LITERATURE MUST BE PRE-APPROVED BY KAWNEER.

EXTERIOR GLASS WEATHER SEAL - SEALANT TO BE A TYPE AS RECOMMENDED BY THE MANUFACTURER OF THE STRUCTURAL SEALANT BEING USED FOR THIS PROJECT. SEALANT MUST BE APPLIED PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS. WEATHER SEAL SEALANT MUST ADHERE TO EXTERIOR GASKET MATERIAL.



Product Engineering & Development

1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS

95449-115
04/21/17


162971 SHEET 01 OF 12

OPEN BACK HORIZONTAL NOTES


THE OPEN BACK HORIZONTAL IS TO BE TYPICALLY USED FOR ALL HEAD/SILL AND LAST BAY INTERMEDIATE HORIZONTALS.

THE OPEN BACK HORIZONTAL CAN BE USED AT OTHER CONDITIONS IF IT IS AN ADVANTAGE TO THE JOB DESIGN.

THE SHEAR BLOCK AT ALL OPEN BACK INTERMEDIATE HORIZONTALS HAS THE OPTION TO BE PRE-INSTALLED INTO THE HORIZONTAL BEFORE HORIZONTALS ARE INSTALLED.



WHEN THE OPEN SIDE OF THE OPEN BACK HORIZONTAL IS EXPOSED AND AT EYE LEVEL A SNAP-IN FILLER IS AVAILABLE.




WHEN THE SNAP-IN FILLER IS NOT USED, AND DUE TO STANDARD COMMERCIAL EXTRUDING TOLERANCES, IT MAY BE REQUIRED TO USE A 4" PIECE OF THE FILLER AT EACH END OF A HORIZONTAL.

USE PART 162316 FOR THE 6" DEEP SYSTEM.
USE PART 162317 FOR THE 7-1/2" DEEP SYSTEM.


OPEN BACK HORIZONTALS AT 90° AND 135° CORNERS

WHENEVER POSSIBLE AVOID USING OPEN BACK HORIZONTALS AT 90° AND 135° CORNERS. IF USING THE OPEN BACK HORIZONTAL BECOMES ABSOLUTELY NECESSARY THE SHEAR BLOCK CONNECTION WILL BE AS SHOWN BELOW.

ALSO REFER TO CORNER INSTRUCTIONS 162973



THE OPEN SIDE OF THE OPEN BACK HORIZONTAL IS TO BE POSITIONED AS SHOWN BELOW. THE INTERMEDIATE HORIZONTAL IS POSITIONED OPEN SIDE DOWN FOR DEAD LOAD SUPPORT.



STEP 1 - CHECK OPENINGS


ELEVATIONS AND SLABS MUST BE WITHIN ADJUSTMENT OF ANCHORING SYSTEM. SEE APPROVED SHOP DRAWINGS FOR ALLOWABLE ADJUSTMENT.

ANCHORING SURFACES OF PERIMETER CONSTRUCTION MUST BE LEVEL AND PLUMB WITHIN THE ADJUSTMENT LIMITS OF THE HEAD, SILL AND JAMB. SEE APPROVED SHOP DRAWINGS FOR ALLOWABLE ADJUSTMENT.

STEP 2 - LAY OUT ANCHOR AND MULLION CENTERLINES

USE WALL LINES ESTABLISHED BY THE GENERAL CONTRACTOR. ON EACH FLOOR LAY OUT A REFERENCE LINE TO ESTABLISH IN AND OUT WALL LOCATIONS.

USE COLUMN CENTER LINES ESTABLISHED BY THE GENERAL CONTRACTOR. ON EACH FLOOR LAY OUT MULLION CENTER LINES AND ANCHOR CENTER LINES.



STEP 3 - INSTALL PRE-SET ANCHORS IF APPLICABLE

USING LOCATION LINES PREVIOUSLY ESTABLISHED INSTALL PRE-SET ANCHORS IN PLACE PER APPROVED SHOP DRAWINGS.



1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS

Product Engineering & Development

95449-115
04/21/17

162971 SHEET 02 OF 12

STEP 4 - FRAME ASSEMBLY


ATTACH ANCHORS TO MULLIONS WHERE APPLICABLE.

ANCHOR PREP MAY BE FABRICATED IN THE FIELD OR FACTORY. CONSULT APPROVED SHOP DRAWINGS FOR CORRECT METHOD.

STANDARD ANCHOR PREP IS THRU-BOLTED AT INTERMEDIATE VERTICALS AND TAPPING PLATES ARE USED AT JAMB VERTICALS. REFER TO APPROVED SHOP DRAWINGS FOR CORRECT METHOD.

WHEN WELDING ANCHORS, PROTECT INSTALLED GLASS AND METAL FROM WELD SPLATTER.



DETAILS SAME FOR "CAPTURED VERTICALS"



DO NOT OVER TIGHTEN ANCHOR CONNECTIONS. TIGHTEN TO A "SNUG TIGHT" POSITION WITH PARTS BROUGHT INTO GOOD CONTACT. BE SURE ANY SPRING TYPE LOCK WASHERS ARE COMPRESSED. THEN TIGHTEN APPROXIMATELY 1/2 MORE TURN.

ATTACH SHEAR BLOCKS. STRUCTURAL GLAZED VERTICAL


DETAILS SIMILAR FOR "CAPTURED VERTICALS"



REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS HEAD AND SILL SHEAR BLOCKS 162384 (6" SYSTEM) 162385 (7 1/2" SYSTEM)

STEP 4 - FRAME ASSEMBLY


ATTACH SHEAR BLOCKS



HEAD/SILL SHEAR BLOCK/ANCHOR WHERE APPLICABLE AND SHOWN BELOW


- 162314 (6" SYSTEM AT JAMBS)
- 162315 (7-1/2" SYSTEM AT JAMBS)
- 162342 (6" SYSTEM AT MULLIONS)
- 162343 (7-1/2" SYSTEM AT MULLIONS)

STRUCTURAL INTEGRITY OF ANCHOR AND FASTENERS MUST BE CHECKED BY FACTORY ENGINEERS




STEP 5 - INSTALL THERMAL BREAK


CAPTURED VERTICALS/HORIZONTALS



STEP 5 - INSTALL THERMAL BREAK



FOR CAPTURED VERTICALS
INSTALL HEAD AND SILL END CAPS 162388 (1" FRAMING) 162389 (1/4" FRAMING) SET IN SEALANT




STEP 6 - PERIMETERS WHERE APPLICABLE

INSTALL PERIMETER MEMBERS PER APPROVED SHOP DRAWINGS. PERIMETER MEMBERS CAN OCCUR AT HEAD, SILL OR JAMB CONDITIONS.

BENCHMARK TO FACE OF PERIMETER MEMBER PER APPROVED SHOP DRAWINGS


CONTINUOUS "F" PERIMETER
162017 (1" GLASS)
162176 (1/4" GLASS)



STEP - 7 INSTALL VERTICAL MULLIONS

DIMENSION BUILDUP CHECK

CHECK OVERALL FRAME DIMENSIONS ABOUT EVERY FIVE MULLIONS ON LONG RUNS. THIS IS TO AVOID DIMENSION BUILDUP.



1600 WALL SYSTEM™2 CURTAIN WALL INSTALLATION INSTRUCTIONS

Product Engineering & Development

95449-115
04/21/17

STEP 7 - INSTALL VERTICAL MULLIONS


STRUCTURAL GLAZED VERTICALS

DETAILS SIMILAR FOR "CAPTURED VERTICALS"




"F" OR "T" ANCHORS WHERE APPLICABLE

"F" AND "T" ANCHOR FASTENER LOCATIONS PER APPROVED SHOP DRAWINGS

REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS




THESE SHEAR BLOCKS MAY NEED TO BE REMOVED TO INSTALL AN ANCHOR FASTENER THAT MIGHT BE LOCATED CLOSE TO THE MULLION



"F" AND "T" ANCHOR FASTENER LOCATIONS PER APPROVED SHOP DRAWINGS

AT MULLION JAMB SIDE, APPLY (2) 128396 SCREWS AS SHOWN TO CENTER F-CLIPS AS REQUIRED.



STEP 7 - INSTALL VERTICAL MULLIONS


STRUCTURAL GLAZED VERTICALS

DETAILS SIMILAR FOR "CAPTURED VERTICALS"

HEAD/SILL SHEAR BLOCK/ANCHOR WHERE APPLICABLE


CAN NOT BE USED WITH EXTERIOR FRAME PERIMETERS SHOWN ON INSTRUCTIONS 162983

162314 (6" SYSTEM) AT JAMBS
162315 (7-1/2" SYSTEM) AT JAMBS
162342 (6" SYSTEM) AT MULLIONS
162343 (7-1/2" SYSTEM) AT MULLIONS



128396 SCREWS #12 x 7/16" PAN HEAD TYPE B


128284 SCREWS #12 x 1-1/2" FLAT HEAD TYPE AB FOR HORIZONTAL ATTACHMENT




THE ABOVE SCREWS ARE ONLY USED AT THE OPTIONAL SHEAR BLOCK/ANCHORS.

STRUCTURAL SHIMMING IS REQUIRED AT SILL TO ACCOMPLISH DESIGNED PERIMETER SEAL WIDTH.

ANCHOR FASTENER LOCATIONS PER APPROVED SHOP DRAWINGS




ANCHOR FASTENER LOCATIONS PER APPROVED SHOP DRAWINGS




STEP 7 - INSTALL VERTICAL MULLIONS

CAPTURED VERTICALS


VERTICAL SPLICE JOINTS WHERE APPLICABLE



SLEEVE IS FACTORY TAPED INTO THE BOTTOM OF THE TOP VERTICAL



REMOVE THE TAPE AND LET THE SLEEVE SLIDE DOWN TO THE FACTORY APPLIED STOP SCREW



FIELD APPLIED FIXING SCREW 128348 #10 x 1-1/4" FLAT HEAD SELF DRILLING

SHOP APPLIED STOP SCREW 128267 #12 x 1" PAN HEAD TYPE AB


USE TEMPORARY SPACERS FOR JOINT DIMENSION

SPLICE JOINT WHEN IT OCCURS AT A HORIZONTAL


STEP 7 - INSTALL VERTICAL MULLIONS

STRUCTURAL GLAZED VERTICALS

VERTICAL SPLICE JOINTS WHERE APPLICABLE



SLEEVE IS FACTORY TAPED INTO THE BOTTOM OF THE TOP VERTICAL



REMOVE THE TAPE AND LET THE SLEEVE SLIDE DOWN TO THE FACTORY APPLIED STOP SCREW

USE TEMPORARY SPACERS FOR JOINT DIMENSION

FIELD APPLIED FIXING SCREW 128348 #10 x 1-1/4" FLAT HEAD SELF DRILLING

SHOP APPLIED STOP SCREW 128267 #12 x 1" PAN HEAD TYPE AB



1600 WALL SYSTEM™2 CURTAIN WALL INSTALLATION INSTRUCTIONS

Product Engineering & Development

95449-115
04/21/17


162971 SHEET 04 OF 12

STEP 8 - INSTALL HEAD/SILL AND INTERMEDIATE HORIZONTALS

TUBULAR HORIZONTALS

STRUCTURAL GLAZED VERTICALS

DETAILS SAME FOR "CAPTURED VERTICALS" EXCEPT HORIZONTAL THERMAL BREAK CUT 1/4" SHORT EACH END.




STEP 8 - INSTALL HEAD/SILL AND INTERMEDIATE HORIZONTALS

REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS


OPEN BACK HORIZONTALS AND LAST BAY HORIZONTALS. FILLER AVAILABLE WHEN OPEN BACK IS EXPOSED AND AT EYE LEVEL.

STRUCTURAL GLAZED VERTICALS


DETAILS SAME FOR "CAPTURED VERTICALS" EXCEPT HORIZONTAL THERMAL BREAK CUT 1/4" SHORT EACH END.



INSTALLING CEILING INTERMEDIATE OPEN BACK HORIZONTAL



INSTALLING STOOL INTERMEDIATE OPEN BACK HORIZONTAL





STEP - 9 INSTALL JOINT PLUGS



CAPTURED GLAZED VERTICALS

ALL SURFACES AND GROOVES MUST BE CLEANED PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS.


JUST BEFORE INSTALLING JOINT PLUGS APPLY SEALANT AS SHOWN FILLING GASKET POCKET AND ADAPTER GROOVE.



162971 SHEET 05 OF 12



JOINT PLUG
162321 (1" FRAMING)
162322 (1/4" FRAME MEMBERS)



APPLY SEALANT TO THIS FACE OF JOINT PLUG

SEAL AROUND JOINT PLUG EDGES AND COMPLETELY OVER JOINT PLUG WITH SEALANT AND TOOL AS SHOWN

SEAL AROUND JOINT PLUG EDGES AND COMPLETELY OVER JOINT PLUG WITH SEALANT AND TOOL AS SHOWN

REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS

KAWNEER
AN ARCONIC COMPANY

Product Engineering & Development


95449-115
04/21/17

1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS

162971 SHEET 05 OF 12

STEP 9 - INSTALL JOINT PLUGS


STRUCTURAL GLAZED VERTICALS



STEP 10 - INSTALL PERIMETER FILLERS AND SPANDREL ADAPTERS WHERE APPLICABLE


CAPTURED VERTICALS

ALL SURFACES AND GROOVES MUST BE CLEANED PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS.




STEP 10 - INSTALL PERIMETER FILLERS AND SPANDREL ADAPTERS WHERE APPLICABLE

CAPTURED VERTICALS



STEP 10 - INSTALL PERIMETER FILLERS AND SPANDREL ADAPTERS WHERE APPLICABLE

STRUCTURAL GLAZED VERTICALS




1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS

Product Engineering & Development

95449-115
04/21/17

STEP 11 - SEAL INTERIOR OF VERTICAL SPLICE JOINTS

CAPTURED VERTICALS



STEP 12 - INSTALL INTERIOR GLAZING GASKETS

GASKETS SHOULD BE INSTALLED JUST PRIOR TO GLASS TO AVOID CONTAMINATION BY JOB SITE DEBRIS. GASKET GROOVES AND POCKETS SHOULD BE CLEAN.

IN TEMPERATURES COLDER THAN 50° F ARRANGEMENTS SHOULD BE MADE TO WARM GASKETS BEFORE INSTALLATION. THIS WILL PREVENT EXCESSIVE GLAZING PRESSURE ON THE GLASS DUE TO COLD, STIFF RUBBER GASKETS.


GASKETS CAN BECOME DEFORMED DURING STORAGE IN CARTONS. THEY SHOULD BE REMOVED FROM CARTONS SEVERAL HOURS PRIOR TO GLAZING AND LAID FLAT OR HUNG TO ALLOW RECOVERY OF CORRECT SHAPE. TEMPERATURES SHOULD BE AT LEAST 50° F TO ALLOW THIS.

027-850 GASKET INSTALLED LENGTH TO BE DAYLITE OPENING. GASKETS TO BE CUT LONG FOR SOME "CROWD-IN". GASKETS SHOULD NEVER BE "STRETCHED TO FIT".


"CROWD-IN" TO BE 1/8" PER FOOT UP TO 5'-0", 3/16" PER FOOT UP TO 8'-0", 1/4" PER FOOT OVER 8'-0".

GASKET'S LENGTH AT STRUCTURAL GLAZED VERTICALS TO BE DAYLITE OPENING PLUS 1-3/8".


CAPTURED VERTICALS



TYPICAL




PERIMETER WHERE APPLICABLE



STEP 12 - INSTALL INTERIOR GLAZING GASKETS

CAPTURED VERTICALS





STEP 12 - INSTALL INTERIOR GLAZING GASKETS

STRUCTURAL GLAZED VERTICALS

ALL SURFACES AND GROOVES MUST BE CLEANED PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS

JUST BEFORE INSTALLING VERTICAL AND HORIZONTAL GASKETS FACE SEAL JOINTS AT ALL (4) CORNERS. ALSO SEAL SCREW HEAD AT TOP HALF OF HORIZONTAL.



1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS


Product Engineering & Development

95449-115
04/21/17

162971 SHEET 07 OF 12

STEP 12 - INSTALL INTERIOR GLAZING GASKETS


STRUCTURAL GLAZED VERTICALS



STEP 14 - INSTALL SETTING BLOCKS

STRUCTURAL GLAZED VERTICALS


DETAILS SIMILAR FOR "CAPTURED VERTICALS"



STEP 15 - INSTALL EXTERIOR GASKETS INTO PRESSURE PLATES


REFERENCE GASKET NOTES IN STEP 12
SAME NOTES APPLY.

REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS



STEP 16 - INSTALL GLASS

CAPTURED VERTICALS




STEP 13 - INSTALL INTERIOR SPONGE AIR SEALS

1" FRAMING MEMBERS

APPLY BOND BREAKER TAPE TO SLEEVE FACE AND SEAL MULLION JOINT. INSTALL 426318 SPONGE AIR SEAL

USE 426319 SPONGE AIR SEAL AT 1" INFILLS/1" FRAMING 1/4" INFILLS/1/4" FRAMING



1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS


Product Engineering & Development

95449-115
04/21/17

162971 SHEET 08 OF 12

STEP 16 - INSTALL GLASS

STRUCTURAL GLAZED VERTICALS




STRUCTURAL GLAZED VERTICALS

TEMPORARY RETAINERS FOR STRUCTURAL GLAZED VERTICALS.

THE LOCATION OF TEMPORARY EXTERIOR INFILL RETAINERS SHOULD BE AT A MAXIMUM SPACING OF 30" ON CENTER.

IF WINDS GREATER THAN 50 MPH (80KPH) ARE EXPECTED, ADDITIONAL TEMPORARIES MAY BE REQUIRED. CONSULT YOUR SEALANT AND/OR INFILL SUPPLIER FOR SPACING RECOMMENDATIONS.

GLAZING TEMPORARY
162353



INSTALL WITH SCREWS 128400 AT 1" GLASS #12 X 2-1/4 PH HD TYPE B USE SCREW 128-284 AT 1/4" GLASS #12 X 1-1/2 FL HD TYPE AB

AT CORNERS AND SPLAYS RETAINERS SHOULD BE MADE FROM A GOOD QUALITY HARDWOOD. THESE RETAINERS ARE NOT SUPPLIED BY KAWNEER.


STEP 17 - INSTALL EXTERIOR PRESSURE PLATES



RECOMMEND USING TORQUE LIMIT TOOL 162399 (SEE NOTE)

HOW TO SET TORQUE LIMIT

- 1) ATTACH ANY CALIBRATED TORQUE INDICATOR TO OUTPUT STUB (1) AND DETERMINE PRESENT TORQUE SETTING WHILE HOLDING THE BODY (5), OR VICE-VERSA
- 2) REMOVE SNAP RING (2) AND LOCKING PLATE (3).
- 3) ADJUST NUT (4) WITH OPEN-END WRENCH: CLOCKWISE TO INCREASE TORQUE, COUNTER-CLOCKWISE TO DECREASE TORQUE.
- 4) OBTAIN NEW TORQUE READING WITH THE CALIBRATED TORQUE INDICATOR. REPEAT PRECEDING STEP IF MORE ADJUSTMENT IS NECESSARY TO REACH DESIRED LIMIT.
- 5) REPLACE LOCKING PLATE INTO NOTCHES AND INSTALL SNAP RING. IF LOCKING PLATE DOES NOT "SEAT", MOVE THE ADJUSTING NUT SLIGHTLY UNTIL IT DROPS IN PLACE. THE DIRECTION IS BEST DETERMINED BY WHETHER A MINIMUM TORQUE APPLICATION OR A MAXIMUM ONE IS DESIRED.



INSTALL PRESSURE PLATES USING SCREWS 128406 1/4-14 X 1" HEX WASHER HEAD TYPE AB.


SCREWS ARE TO BE LOCATED 9" ON CENTER. ALWAYS LOCATE A SCREW AS CLOSE AS POSSIBLE TO A HORIZONTAL JOINT. THIS WILL PROVIDE MAXIMUM PRESSURE FOR THE CRITICAL JOINT SEALS.

INSTALL HORIZONTAL PRESSURE PLATES WITH WEEP HOLES TOWARDS TOP OF HORIZONTAL.

AT EACH HORIZONTAL AND VERTICAL PRESSURE PLATE INSTALL TWO SCREWS PART WAY, THEN INSTALL THE THIRD SCREW ALL THE WAY, AND THEN TIGHTEN THE FIRST TWO SCREWS. THIS ELIMINATES LATERAL WALKING OF THE PRESSURE PLATE POSITION.


TORQUE ALL SCREWS TO 95 TO 100 INCH POUNDS. DURING COLD WEATHER, TORQUE SCREWS TO 50 INCH POUNDS UNTIL ALL 4 SIDES HAVE BEEN CLAMPED. THEN TORQUE SCREWS TO 95 TO 100 INCH POUNDS.

CAPTURED VERTICALS



JUST BEFORE INSTALLING VERTICAL PRESSURE PLATES APPLY A GENEROUS AMOUNT OF SEALANT TO THE JOINT PLUG FACE FILLING JOINTS AS SHOWN


CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS



INSTALL VERTICAL PRESSURE PLATES AT CAPTURED VERTICALS


NOTE - THE TORQUE LIMIT TOOL WAS DESIGNED TO BE USED WITH A HAND DRIVEN DEVICE. THE TOOL CAN BE ADAPTED TO A DRILL MOTOR IF USED AT A MAXIMUM SPEED OF APPROXIMATELY 300 RPM. HIGHER SPEEDS CAN CAUSE OVERHEATING AND AFFECT THE ACCURACY. AFTER APPROX. 1 HOUR OF TOOL USAGE CHECK TORQUE SETTINGS WITH A TORQUE WRENCH.

INTERMEDIATE HORIZONTAL VISION OVER SPANDREL



TOOL EXCESS SEALANT


HEAD CONDITION SILL SAME



TOOL EXCESS SEALANT

PERIMETER FILLER

HEAD CONDITION SILL SAME



TOOL EXCESS SEALANT



1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS


Product Engineering & Development

95449-115
04/21/17


STEP 17 - INSTALL EXTERIOR PRESSURE PLATES

INSTALL VERTICAL PRESSURE PLATES AT CAPTURED VERTICALS

VERTICAL EXPANSION JOINTS



AT TOP PRESSURE PLATE LOCATE SCREW CLOSE TO THE MULLION JOINT BUT NOT BELOW THE JOINT




CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS

COMPLETELY SEAL JOINT. DO NOT LET SEALANT INTERFERE WITH COVER SNAP OVERLAP PRESSURE PLATE FACE CREATING A BAND-AID SEAL.


INSTALL HORIZONTAL PRESSURE PLATES AT CAPTURED VERTICALS

CENTER HORIZONTAL PRESSURE PLATES SO END GAPS ARE EQUAL.




INTERMEDIATE HORIZONTAL VISION OVER SPANDREL

SEAL JOINTS AS SHOWN. TOOL SEALANT. THIS SEAL IS TO JOIN AND ADHERE TO THE JOINT PLUG SEALS.



CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS

DO NOT LET THE SEAL INTERFERE WITH THE COVER SNAP.



GASKET 027850


B-B

GASKET 027850

FACE VIEW

PERIMETER FILLER

HEAD HORIZONTAL SILL SAME




SEAL JOINTS AS SHOWN. TOOL SEALANT. THIS SEAL IS TO JOIN AND ADHERE TO THE JOINT PLUG SEALS.


REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS

SEAL BETWEEN PRESSURE PLATE AND HEAD/SILL END CAP AS SHOWN.

HEAD HORIZONTAL SILL SAME




SEAL JOINTS AS SHOWN. TOOL SEALANT. THIS SEAL IS TO JOIN AND ADHERE TO THE JOINT PLUG SEALS.



CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS

DO NOT LET THE SEAL INTERFERE WITH THE COVER SNAP.



VERTICAL GASKET STOPS 1" SHORT OF END

GASKET 027857


E-E

GASKET 027850

GASKET 027850

FACE VIEW


DO NOT LET THE SEAL INTERFERE WITH THE COVER SNAP



C-C GASKET 027850


INSTALL HORIZONTAL PRESSURE PLATES AT SSG VERTICALS

NOTE: THE TORQUE LIMIT TOOL WAS DESIGNED TO BE USED WITH A HAND DRIVEN DEVICE. THE TOOL CAN BE ADAPTED TO A DRILL MOTOR IF USED AT A MAXIMUM SPEED OF APPROXIMATELY 300 RPM. HIGHER SPEEDS CAN CAUSE OVERHEATING AND AFFECT THE ACCURACY. AFTER APPROXIMATELY 1 HOUR OF TOOL USAGE CHECK TORQUE SETTINGS WITH A TORQUE WRENCH.



JUST BEFORE APPLYING PRESSURE PLATE APPLY A GENEROUS AMOUNT OF SEALANT TO THE JOINT PLUG FACE

CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS






1600 WALL SYSTEM™2 CURTAIN WALL INSTALLATION INSTRUCTIONS

Product Engineering & Development

95449-115 04/21/17

STEP 17 - INSTALL EXTERIOR PRESSURE PLATES

INSTALL HORIZONTAL PRESSURE PLATES AT SSG VERTICALS






COMPLETELY SEAL HORIZONTAL PRESSURE PLATE JOINT. DO NOT LET SEALANT INTERFERE WITH COVER SNAP.

CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS.

INSTALL HORIZONTAL PRESSURE PLATES AT SSG VERTICALS




REFERENCE INSTRUCTIONS 162983 FOR EXTERIOR FRAME PERIMETERS



COMPLETELY SEAL HORIZONTAL PRESSURE PLATE JOINT. DO NOT LET SEALANT INTERFERE WITH COVER SNAP.

CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS.

INSTALL HORIZONTAL PRESSURE PLATES AT SSG VERTICALS




COMPLETELY SEAL HORIZONTAL PRESSURE PLATE JOINT. DO NOT LET SEALANT INTERFERE WITH COVER SNAP.

CLEAN JOINT PER SEALANT MANUFACTURER'S RECOMMENDATIONS.

STEP 18 - INSTALL PERIMETER SEALS

PERIMETER WEATHER SEALS ARE INSTALLED AT THE PRESSURE PLATE LOCATION AS DETAILED BELOW. (THIS SEAL SHOULD BE INSTALLED BEFORE COVERS ARE APPLIED WHEN COVERS DEEPER THAN 3/4" ARE USED) EXTERIOR COSMETIC SEALS AT THE COVER MAY BE APPLIED AT THE HEAD AND JAMBS ONLY. SILL COVERS MUST REMAIN OPEN TO ALLOW WATER DRAINAGE TO THE EXTERIOR.



1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS

Product Engineering & Development


95449-115
04/21/17

162971 SHEET 11 OF 12


STEP 19 - INSTALL EXTERIOR COVERS

CAPTURED VERTICALS

CARE MUST BE TAKEN TO AVOID DAMAGE TO COVERS DURING INSTALLATION. USE A 18" LONG PIECE OF 2" X 4" WOOD ALONG WITH A HAMMER OR MALLET TO SEAT THE COVER.





PINNING OF ALL VERTICAL COVERS IS REQUIRED FOR BOTH SIDES. DRILL A .106 DIA. HOLE (#36 DRILL) AND INSTALL 128920 SCREWS #6 X 3/8" PAN HEAD TYPE B. LOCATE PINNING AT A HORIZONTAL CLOSEST TO THE COVER HEIGHT CENTER.



NOTE FOR 5" SIGHTLINE COVERS


DUE TO LARGE EXTRUSION TOLERANCES, 5" SIGHTLINE COVERS MAY REQUIRE SEALANT OR PINNING TO HOLD IN PLACE.

INSTALL HORIZONTAL COVERS WITH THE WEEP HOLES DOWN




STRUCTURAL GLAZED VERTICALS

INSTALL HORIZONTAL COVERS WITH THE WEEP HOLES DOWN



REMOVING COVERS


COVERS CAN BE SAVED IF TOLERANCES ARE NOT TOO TIGHT AND THE COVER IS REMOVED WITH EXTREME CARE



STEP 20 - INSTALL STRUCTURAL AND WEATHER SEALS

KAWNEER DOES NOT SUPPLY SEALANT. SEALANT TO BE SILICONE AS RECOMMENDED BY THE SEALANT MANUFACTURER. INFILL AND METAL TO BE CLEANED PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS. SEALANT BACKUP ROD TO BE PER THE SEALANT MANUFACTURER'S RECOMMENDATIONS.

FILL SPACE BETWEEN INSULATED UNITS AND BEHIND SINGLE GLAZED UNITS WITH RECOMMENDED BACKUP ROD. APPLY STRUCTURAL SEAL AND WEATHER SEAL AS SHOWN. ALLOW STRUCTURAL SEAL TO CURE PER SEALANT MANUFACTURER'S RECOMMENDATIONS. THEN REMOVE TEMPORARY RETAINERS, SEAL FASTENER HOLES AND FILL WEATHER SEAL HOLES.



EXTERIOR STRUCTURAL SEAL MUST BE APPLIED IN THREE STEPS. EACH SIDE SEPARATELY THEN THE WEATHER SEAL.



1600 WALL SYSTEM™2
CURTAIN WALL
INSTALLATION
INSTRUCTIONS

Product Engineering & Development

95449-115
04/21/17

162971 SHEET 12 OF 12